

INVESTMENT GRADE ENERGY AUDIT REPORT
of Centurion University of Technology & Management
Balangir



Submitted to:

Centurion University of Technology & Management

Behind BSNL Office, IDCO land
Rajib Nagar, Balangir, Odisha- 767001
Tel - 06652-235641/235642/235644
Mobile: 9437037148
E-mail: pradip.sarangi@cutm.ac.in
Website: www.cutm.ac.in



Power Tech



Submitted by:

M/s. Swain & Sons Power Tech Pvt. Ltd.

Corporate Office: K-8-82, Kalinga Nagar, Ghatikia
Bhubaneswar-751029, Odisha

Phone: 0674-2954256, Mob: 9438747172, 8093533005, 9937159760

Email: sspt12@gmail.com, info@pwrtech.com

Website: www.pwrtech.com

Table of Contents

ACKNOWLEDGEMENT	5
AUDIT TEAM DETAILS	6
CERTIFICATE	7
EXECUTIVE SUMMARY	8
1.0 INTRODUCTION.....	10
1.1. About the Site.....	11
1.2. Scope of Work	11
1.3. Methodology.....	13
Instruments Used	14
2.0 BRIEF DESCRIPTION OF THE UNIVERSITY	14
2.1 Major Utilities.....	15
3.0 ENERGY SCENARIO	16
3.1 Analysis of Energy Bill.....	17
3.2 Base Line Energy Consumption and Specific Energy Consumption.....	20
3.3 Electrical Distribution System and Water Distribution System	24
3.4 Transformer Details	26
3.5 Study of Voltage, Current, Power Factor Profile	27
4.0 LIGHTING SYSTEM	32
4.1 Lighting Inventory	32
4.2 ENCON option for lighting system.....	34
4.3 O & M Practice, Energy Accounting and Monitoring For Lighting System.....	35
4.4 Illumination Survey and LUX Level Measurement	36
4.5 ENCON Option for Installation of Solar Water Heater.....	37
4.6 ENCON Option for Installation of Solar Power Plant in Net Metering Concept.....	37
5.0 HVAC System.....	40
5.1. ENCON Option for Installation of AC Saver for old 1.5 Ton AC.....	40
5.2 Advantages of Inverter Air Conditioner	43
5.3 Maintenance Tips for Split / Window AC	44
6.0 Fan Inventory.....	45
7.0 DIESEL GENERATING (DG) SET	46
7.1 Observation & Analysis for DG Set	46
7.2 Recommendation.....	47
8.0 TRANSPORTATION	47
9.0 WATER PUMPING SYSTEMS.....	48
9.1 Water Pumping Storage and Distribution System	48

9.2	Utilization of water Pumping System.....	48
9.3	Rain Water Harvesting System	48
9.4	Sewage Treatment Plant	49
9.5	Operation and Maintenance of CUTM	49
9.6	Energy Monitoring & Accounting System.....	49
10.0	TECHNICAL SPECIFICATIONS FOR ENERGY EFFICIENT PRODUCT	51
11.0	MOU Format with EESL.....	55
12.0	ENERGY MANAGEMENT POLICY	58
Annexure:	60
13.0	Vender Details of Projects	63

LIST OF ABBREVIATIONS

AC	: Air Conditioning
BEE	: Bureau of Energy Efficiency
LED	: Light Emitting Diode
CTR	: CT Ratio
DB	: Distribution Board
DG	: Diesel Generator
ENCON	: Energy Conservation
Hrs	: Hours
HT	: High Tension
I	: Current
V	: Voltage
kL	: Kilo Liter
kV	: Kilo Volt
KVA	: Kilo Volt Ampere
kVAh	: Kilo Volt Ampere Hour
kVAR	: Kilo Volt Ampere Reactive
kW	: Kilo Watt
kWh	: Kilo Watt Hour
THD	: Total harmonic distortion
LT	: Low Tension
PF	: Power Factor
PTR	: PT Ratio
SEC	: Specific Energy Consumption
TF	: Transformer
UF	: Utilization Factor

ACKNOWLEDGEMENT

Swain & Sons Power Tech Pvt. Ltd. (SSPTPL) places on record its sincere thanks to Centurion University of Technology & Management for entrusting the task of conducting the Investment Grade Energy Audit of Centurion University of Technology & Management (CUTM), Balangir.

SSPTPL acknowledges with gratitude the wholehearted support and encouragement given by all CUTM officials while carrying out the energy efficiency study at CUTM.

SSPTPL acknowledges with gratitude and sincerely thanks all the officials and staff members of Centurion University of Technology & Management who have rendered their all-possible co-operation and assistance to the study team during the entire period of the Audit.

Our special thanks to Mr. Pradeep Ku Sarangi (Regional Director), Mr. Somanath Sarangi (Principal, SOAs), Mr. Bibhu M.P. Tripathy (Office Superintendent) and the Energy Conservation Cell Members for their whole hearted co-operation and guidance in carrying out the Investment Grade Energy Audit of CUTM, Balangir.

Signature



Subhranshu Sekhar Rath
General Manager

Swain & Sons Power Tech Pvt. Ltd.

Empanelled ESCO by BEE, Ministry of Power- CRISIL SME GRADING:CRISIL-BEE Grade 3
K-8-82, Kalinga Nagar, Ghatikia, Bhubaneswar-751029, Odisha

Phone: 0674-2954256

Mobile: 8093533005, 9438747172

Email: sspt12@gmail.com, info@pwrtch.com

Website: www.pwrtch.com

AUDIT TEAM DETAILS

1. Mr. Subhranshu Sekhar Rath, General Manager
2. Mr. Nilamani Behera, Sr. Consultant, Energy Auditor Regd. No. -EA-9407
3. Mr. Suresh Gurjar, Manager
4. Mr. Nirjhar Biswal, Assistant Manager (Project)
5. Mr. Suraj Kumar Bhujabala, Assistant Manager (Project)
6. Mr. Subash Mallick, Project Associate
7. Ms. Lalita Kumari Swain, Project Associate

We express our sincere thanks to the following students of CUTM, Bhubaneswar for showing their interest and involvement in conducting the energy audit of CUTM, Balangir campus.

Sl.	Name	Enrolment No
1	Ms. Riya Saha	200301150006
2	Mr. Rohit Mishra	200301150002
3	Mr. Siddharth Singh	200301150003
4	Mr. Azharhul Haque	200301151016
5	Mr. Pradeepta Kumar Mohanta	200301150012
6	Mr. Chandrasekhar Maharana	200301151017
7	Mr. Anirban Hatui	200301150011
8	Mr. Papu Jagganath Rao	200301150007
9	Mr. B. Sai	200301151015

CERTIFICATE

We certify the following

- The data collection has been carried out diligently and truthfully.
- All data measuring devices used by the auditor are in good working condition, have been calibrated and have valid certificate from the authorized approved agencies and tampering of such devices has not occurred.
- All reasonable professional skill, care and diligence had been taken in preparing the energy audit report and the contents thereof are a true representation of the facts.
- The investment grade energy audit has been carried out in accordance with the BEE prescribed norms.

Signature



Subhranshu Sekhar Rath
General Manager

Swain & Sons Power Tech Pvt. Ltd.

Empanelled ESCO by BEE, Ministry of Power- CRISIL SME GRADING:CRISIL-BEE Grade 3
K-8-82, Kalinga Nagar, Ghatikia, Bhubaneswar-751029, Odisha

Phone: 0674-2954256

Mobile: 8093533005, 9438747172

Email: sspt12@gmail.com, info@pwrtech.com

Website: www.pwrtech.com

EXECUTIVE SUMMARY

The journey of Centurion University of Technology and Management (CUTM) began in the year 2005 by a group of ambitious academics with aspirations to provide high quality education both nationally and internationally. The first step in this direction was to take over an ailing engineering Institute, the Jagannath Institute for Technology and Management (JITM) in one of the most challenging tribal districts of Odisha and one which was considered to be a left-wing extremist affected area. Subsequently, JITM was transformed into Centurion University of Technology and Management (CUTM) in August 2010, through an act of Odisha Legislative Assembly. It became the First Multi-Sector State Private University in Odisha. The campus is spread over 15 acres. The complex includes School of Applied Sciences and School Of Pharmacy. The CUTM Balangir Campus is located in the heart of the Balangir City which is well connected by rails and roadways.

Goals and Objectives of the Energy Management Programme:

The Investment Grade Energy Audit of Centurion University of Technology & Management, Balangir was carried out during the period of July 2022. Energy Conservation is a major focus and requirement in Institutional, Commercial and Government Buildings, and hence the management of Centurion University of Technology & Management, has entrusted the work of conducting Investment Grade Energy Audit (IGEA) of their entire campus to Swain & Sons Power Tech Pvt. Ltd. The main focus of the audit was to establish Specific Energy Consumption for all the Buildings & Vehicles for last financial year 2021-22, collection of technical information like specification of the machines, details of all the buildings, fuel consumption in all the DG, water consumption details, etc.

Centurion University of Technology & Management, Balangir is availing power supply from TPWODL, local DISCOM Connections at 11 kV Voltage level and through a 100 KVA power transformer with contract demand of 35 kW (Consumer no. 911001030356).

SUMMARY OF THE ENERGY BILLS FOR THE LAST FINANCIAL YEAR OF CUTM BALANGIR

Year	Description	Electricity consumed in kWh	Avg. MD in kVA	Power Factor	Load Factor	Energy Bill in Rs.	Energy Charge in Rs./kWh
For Financial year 2021-22	Monthly average	8571	50	0.99	2.92	68858	7.6
	Daily Average	286	50	0.99	2.92	2295	7.6

The major utilities of Centurion University of Technology & Management, Balangir are Electricity, Water and HSD. The electricity is utilized for Lighting, Fans, Pumping of water, Computer, Printer, Laboratory, Water cooler, Fridge, Projector, Speaker and AC. HSD is utilized in DG set and Transportation Vehicles. Water consumption is there in all the buildings for day-to-day domestic purposes and also for plantation, gardening and cleaning.

During the study, various energy conservation options were identified, their cost benefit analysis was found out and same is furnished below. It is recommended that CUTM may implement the Energy Conservation Option as suggested in the report.

Details of Energy Conservation measures / Recommendations of Accredited Energy Auditor for Improving Energy Efficiency						
[See rule 3(1) (c)]						
Energy Saving measures	Anticipated Investment (In Lakh)	Anticipated Annual Savings (In Lakh)	Simple Pay Back Period in Year	Anticipated Annual Energy Savings		
				Electricity in kWh	Thermal Energy in kcal	Equivalent Energy in TOE
Installation of Roof top Solar Power Plant	30	5.99	5.0	99864		9
Replacing Conventional Ceiling Fan with 75 W Super Energy Efficient Ceiling Fan	11.27	3.28	3.4	54606		4.7
Replacement of 36W FL Tube Fittings with 20 W LED Tube	1.77	1.7	1.1	28051		2
Installation of Solar Water Heater at CUTM Canteen	0.7	0.6	1.2		7247899	1
Installation Lightpipe Fitting System	1	0.49	2	8448		0.73
Installation of AC Saver for Old 1.5 Ton AC	2	1.4	1.4	23693		2.04
Installation of Light Motion Sensor at Boys Canteen to reduce lighting load	0.042	0.020	2	345		0.030
Total	47	13	3.48	215006	7247899	19

1.0 INTRODUCTION

The Government of India has enacted the Energy Conservation Act, 2001 with the objective of providing sustainable and more efficient management of our energy resources. The aim of Energy Conservation (EC) Act 2001 is to provide the much-needed legal framework and other institutional arrangements so that various energy efficiency improvement drives can be easily launched at the state and national level. In order to implement the various provisions under the EC Act 2001, the Government of India has established the Bureau of Energy Efficiency (BEE), to enact and enforce energy efficiency through various regulatory and promotional measures.

Energy Conservation has become a top most priority in today's scenario in order to have a sustainable growth, productivity, enhancement and Environmental Protection. Considering the vast potential of energy savings and benefits of energy efficiency as per the report prepared by National Development Council (NDC) Committee on power, Govt. of India enacted the Energy Conservation Act 2001. Accordingly, the Govt. of India set up the Bureau of Energy Efficiency (BEE) under the provision of the Energy Conservation Act 2001 for development of policies and strategies with a thrust on self-regulation and market principles, with the primary objective of reducing energy intensity of the Indian Economy.

Buildings consume significant portion of Energy for lighting, Air Conditioning, Ventilation purpose and hence Energy Conservation is a major focus and requirement in Institutional, Commercial and Government Buildings. Besides Building owners are also focusing Energy Conservation and Energy Efficiency in large extent for a higher productivity. Efficient Energy management, Usage of Energy Efficient Technologies and adopting best-practices that would help a Building Owner to reduce their energy cost considerably. Hence in order to identify the energy conservation opportunities and reduce the present energy consumption, the management of CUTM has entrusted the work of conducting Investment Grade Energy Audit (IGEA) to Swain & Sons Power Tech Pvt. Ltd. The Energy Audit of CUTM was carried out in the period of July 2022. The scope of work includes collection of existing layout of Building, Collection of various data including lighting inventory, AC list, Pump, Motor and other electrical load list, Collection of Month wise Energy Bill for FY 2021-22, Power measurement of all running Transformer, Panels, AC, Pump and Motor and submission of Energy Audit Report along with details of Energy Conservation Opportunity.

1.1. About the Site

Situated in the western region of Odisha, the campus is spread over 15 acres of land. The CUTM Balangir Campus is located in the heart of the Balangir City which is well connected by rails and roadways. The journey of Centurion University of Technology and Management (CUTM) started with the takeover of Jagannath Institute for Technology and Management (CUTM) in 2005. Subsequently, CUTM was transformed into Centurion University of Technology and Management in August 2010, through an act of Odisha Legislative Assembly. The complex includes School of Applied Sciences and School of Pharmacy.

1.2. Scope of Work

a) Review of present electricity consumption and fuel oil. Estimation of energy consumption in various loads like lighting, HVAC, DG Set etc in premises of the Building.

b) **Electrical Distribution system:**

- Review of present electrical distribution from the single line diagram (SLD). Study of operation/loading of distribution transformers, cable loading, normal and emergency loads, electricity distribution in various area/ floors and loss estimation.
- Study of reactive power management and option for power factor improvement, functioning of capacitor banks.
- Study of power quality, like harmonics, current unbalance, voltage unbalance etc.
- Exploring the energy conservation options (ENCON) in the electrical distribution system.

c) **Lighting System**

- Review of present lighting system, lighting inventories etc.
- Estimation of lighting load at various locations like different floors, outside (campus) light, pump house and other important locations.
- Detailed illuminations survey with measurement of LUX level at various locations and comparison with acceptable standards.
- Study of present lighting control system, lighting maintenance systems, present procedure for management of lighting spares and consumables and recommendation for improvement
- Analysis of lighting performance indices like LUX/m² LUX/Watt, LUX/Watt/m² and comparison of the same with benchmark.
- Exploring the possibility of retrofitting option with energy efficient lighting system like LED lamp, control Gears, sensors and automators, voltage regulators and solar based system.
- Developing a suitable lighting energy accounting and monitoring system.

- Exploring the energy conservation options (ENCON) in lighting system.

d) Heating Ventilation & Air conditioning system (HVAC system)

- Review of present HVAC system like Spilt AC, Window AC, water coolers and air heater etc.
- Performance assessment of window AC, and Split AC.
- Analysis of HVAC performance like estimation of Energy Efficiency Ratio (EER) i.e. (KW/TR) and comparison of the operating data with the design data and recommendation for best prices/standard requirement.
- Exploring the energy conservation options (ENCON) in HVAC system

e) Diesel Generators (DG) sets

- Review of DG set operation.
- Performance Assessment of DG sets in terms of specific fuel consumption (SFC i.e. kWh/Ltr.), Exploring the energy conservation options (ENCON) in lighting system.
- Exploring the energy conservation options (ENCON) in DG sets.

f) Water pumping system

- Review of water pumping, storage and distribution systems.
- Performance assessment of all major water pumps i.e. power consumption vs. flow delivered, estimation of pump efficiency etc and compare with best practices
- Study of the flow control mechanism.
- Study of rational utilization of water pumping system, energy efficient retrofitting etc.

g) Motor Load survey

- Conducted the motor load survey.
- Survey of motor loading (% loading) for major electrical drives.
- Measurement of all electrical parameters like voltage, current, PF & KW for all running motors and calculation of pump efficiency and suggestions for improvement.
- Study of mechanical power transmission system and suggest for energy efficiency.
- Study of rational usage of drives for reducing electrical energy consumption.

h) Energy Monitoring & Accounting System:

- Detail Review of present energy monitoring & accounting system in terms of metering, record keeping, data logging, periodic performance analysis etc.
- Suggest for procedures for improvement in energy monitoring and accounting system.

i) UPS

- Measurement and analysis of the UPS loading, redundancy, operating efficiency, load pattern to suggest measures for energy cost reduction, measurement and analysis of Harmonics.

j) Others:

- Review of present maintenance practice, replacement policies and building safety practices as applicable to high rise buildings and recommend for improvement.
- Cost benefit Analysis of each ENCON indicating simple payback period.

1.3. Methodology

The following step by step methodology and approach were adopted to carry out the Investment Grade Energy Audit Report of CUTM, Balangir. Prior to energy audit, SSPTPL team made a walk through survey of the Building and associated subsystems to assess the followings:-

- The existing layout of Building.
- Collection of various data including lighting inventory, AC list, Fan list, Motor and other electrical load list.
- Collection of Month wise Energy Bill for FY 2021-22.

The methodology was explained / discussed with CUTM, Balangir officials. The broad methodology adopted for the Energy Audit at CUTM is furnished below.

1. The program of visit of energy audit team to site for carrying out the IGEA work was informed to CUTM, Balangir officials.
2. Data collection and Energy Bill Collection was carried out through discussions with the officials and from past records, log books.
3. Technical specification of equipments and their operating parameters were collected, while visiting the area. The data so collected were analyzed and the deviations were noted.
4. Performance of the major energy consuming equipments was analyzed.
5. Measurement of electrical energy parameters, wherever possible, using portable instruments were carried out.
6. Power Measurement of all running Transformer, Panels, AC was carried out using portable power analyzer brought by PTC for this purpose.
7. Review of present lighting system, lighting inventories collection were carried out. Estimate all lighting load at various locations like different parts of Building, outside area i.e. street lighting and area lighting and other important locations. Also detailed illuminations survey was determined with measurement of LUX level at various locations.

8. Ambient parameters (Temperature, Humidity) were measured using portable test instrument brought by SSPTPL.
9. Energy Conservation option were identified and tabulated on the basis of priority.
10. Draft soft copy of energy audit report comprising of observations and recommendations with adequate financial justification, vendor support data, etc. was prepared and submitted to CUTM, Balangir for acceptance.
11. Final energy audit report was submitted after acceptance of the draft energy audit report.

Instruments Used

SSPTPL have a wide array of latest, sophisticated, portable, diagnostic and measuring instruments to conduct energy audit investigations and analysis. The following special portable instruments are used to carry out various field measurements and analysis during the energy audit period.

- Three Phase Power Analyzer(ALM-30)
- Clamp on electrical power analyzers
- Infrared Non-Contact Thermometer
- Thermal Camera
- Anemometer
- Hygrometer
- LUX Meter
- Power Guard

2.0 BRIEF DESCRIPTION OF THE UNIVERSITY

Name & Address

Centurion University of Technology & Management
Behind BSNL Office, IDCO Land, Indira Nagar, Balangir
Dist: Balangir, Odisha-767001
Tel: 9437293374

Name & Details of the Authorized Signatory of CUTM, Balangir

Mr. Pradeep Kumar Sarangi (Regional Director)
Mobile: 9437037148
E-mail: pradip.sarangi@cutm.ac.in

Name & Details of the Project Coordinator

Mr. Somanath Sarangi (Principal, SOAS)
Mobile: 9437890943
E-mail: somnath@cutm.ac.in

DESCRIPTION OF CAMPUS:

Centurion University of Technology & Management (CUTM) is the first multi-sector state private university in Odisha, located behind BSNL Office, IDCO Land, Indira Nagar Balangir, Odisha 767001, spread over 15 acres. It is the only technological University in South Odisha. It is located at latitude 20°41'17"N & longitude 83°28'33"E. Nearest Railway station is Balangir junction.

The complex includes School of Applied Sciences and School of Pharmacy.

University is having approximately 60 numbers of teaching staff members, 1300 numbers of Students, 47 numbers of non-teaching staff including Electrician, Plumber.

Centurion University of Technology & Management, Balangir is availing power supply from TPWODL, local DISCOM Connections at 11 kV Voltage level and through a 100kVA power transformer and with contract demand of 35 kW (Consumer no. 911001030356). One number of DG Set i.e. of capacity 62.5 kVA is present for providing power supply during emergency .



(Google Earth View of CUTM, Balangir)

2.1 Major Utilities

- Electricity
- Water
- HSD

Electricity:

Electricity is utilized for Lighting, Fans, Pumping of water, Computer, Printer, Laboratory, Water cooler, Fridge, Projector, Speaker and AC, etc.

Water:

Water consumption is in all the Buildings for day to day usage and also utilized in plantation, gardening and cleaning.

HSD:

HSD is consumed in DG set and Transportation.

3.0 ENERGY SCENARIO

CUTM receives the electrical power supply from TPWODL at 11kV. The present contract demand of the Building with TPWODL is 35kW. The energy fact file of the building is furnished below:

Table: Energy Fact File of CUTM, Balangir

Location	Jagannath Institute of Technology & Management (CUTM), At: Industrial Growth Centre, Balangir Pin-767001
Areas of Utilization of Energy	JITM (CUTM), Balangir
Source of Supply	11kV Distribution Line from Rajiv Nagar Substation Of TPWODL
Total Contract Demand	35kW
Major Loads	Lighting & Power, Air Conditioning, Heating & Cooling, Computers, Printers, Fans, Pump, Motor, DG Set, Household Appliances and Other loads
Usage Hours	Mainly 09.00 am to 6.00 pm on all working days
Monthly Energy Consumption	8571 Units
Monthly Energy Bill	Rs. 68858

Building Audit Data Sheet			
Sl. No.	Item	Value	
Size, Age & Construction of the building			
1	Connected Load (kW) or Contract Demand (KW)	35	
2	Installed Capacity: DG Sets (KVA or KW)	62.5	
3	a) Annual Electricity Consumption ,Purchased From Utilities(kWh)	102854	
	Annual Electricity Consumption, Through Diesel Generating DG Set (kWh)	180	
	c) Total Annual Electricity Consumption, Utilities + DG Sets (kWh)	103034	
4	a) Annual Cost Electricity Purchased from Utilities (Rs.)	826297	
5	Working hours (Mainly day working but Library is 24 hour working)	Built Up Area (sq m) (Excluding Basement Area)	10545
6	Working days/week (e.g. 5/6/7 days per week)	6	
7	Installed lighting load(kW)	7.5	
8	Installed capacity of Air Conditioning System(TR)	37.50	
9	Existing EPI(Energy performance Index) in kWh/sq. m/year Energy includes	9.77	
	Electricity Purchased & Generated (Excluding Electricity from any Renewable Source)	102854	
10	No. of Floors per building	2	
11	HSD(in Ltr) in the year for Vehicle	29322.59	
	HSD(in Ltr) in the year for DG Set	600.000	
12	Occupancy Information	Daily Visitors	50
		Staff Members	107

3.1 Analysis of Energy Bill

The energy bills details and tariff categorization details of CUTM, Balangir for FY' 2021-22 having consumer no- 911001030356 is furnished below:

Table: Consumer details of the Building

Consumer Name & Address	JITM (CUTM) at Industrial Growth Centre, Balangir
Tariff Category	GP<110 kVA
Consumer No.	911001030356
Contract Demand	35kW
Supply Voltage	11kV

Data source: Energy Bills of CUTM were collected during the period of Energy audit.

The summary of Energy Bill Analysis of The CUTM, Balangir is furnished below:

Table: Summary of Energy Bill Analysis of CUTM, Balangir

The summary of Energy Bill Analysis of CUTM, Balangir Building is furnished below:

SUMMARY OF THE ENERGY BILLS FOR THE LAST TWO FINANCIAL YEARS OF CUTM BALANGIR							
Year	Description	Electricity consumed in kWh	Avg. MD in kVA	Power Factor	Load Factor	Energy Bill in Rs.	Energy Charge in Rs./kWh
For Financial year 2021-22	Monthly average	8571	50	0.99	2.92	68858	7.6
	Daily Average	286	50	0.99	2.92	2295	7.6


Table: Energy Bill of CUTM, Balangir for FY' 2021-22

SUMMARY OF ENERGY BILL OF THE CUTM BALANGIR FOR FINANCIAL YEAR 2021-22																				
Month	Energy Consumed in kWh	Energy Consumed in kVAh	Av. Load Factor	Av. Power Factor	MD in kW	MD in kVA	Energy Charge in Rs.	Demand Charge in Rs.	PF Penalty (+ve) / PF Incentive (-ve)	Rebate	CSC	TOD Incentive	Overdrawl Penalty	Delay Payment Surcharge	Interest on Security	Meter Rent in Rs.	Electricity Duty	Current Monthly Bill in Rs.	Energy Charge in Rs./kWh	Unit cost in Rs. per kWh
Apr-21	13346	627944	16.4	0.021	1.09	51.6	101304	1410	0	1335	0	0	0	0	0	0	4052	106766	7.6	8
May-21	6510	6536	0.18	0.996	51.39	51.6	49021.3	1410	0	651	0	0	0	0	4886	0	1961	52392	7.5	8
Jun-21	2064	2076	0.05	0.994	51.5	51.8	15512.4	1410	0	206	0	0	0	0	0	0	621	17543	7.5	8.5
Jul-21	5442	0	0	0	0	35	40999.6	1410	0	544	0	0	0	0	0	0	1640	44050	7.5	8.1
Aug-21	10766	652786	17.1	0.016	0.85	51.6	81513.6	1410	0	1076	0	0	0	0	0	0	3261	86184	7.6	8
Sep-21	8586	8608	0.23	0.997	51.47	51.6	64983.9	1410	0	859	0	0	0	0	0	0	2599	68993	7.6	8
Oct-21	11128	11166	0.29	0.997	51.42	51.6	84300.2	1410	0	1113	0	0	0	0	0	0	3372	89082	7.6	8
Nov-21	10130	10162	0.27	0.997	51.43	51.6	76709.6	1410	0	1013	0	0	0	0	0	0	3068	81188	7.6	8
Dec-21	9802	9868	0.26	0.993	51.25	51.6	74202	1410	0	980	0	0	0	0	0	0	2968	78580	7.6	8
Jan-22	5200	5240	0.14	0.992	51.2	51.6	39221.3	1410	0	520	0	0	0	0	0	0	1569	42200	7.5	8.1
Feb-22	3944	3968	0.11	0.994	51.29	51.6	29722.1	1410	0	394	0	0	0	0	0	0	1189	32321	7.5	8.2
Mar-22	15936	0	0	0	0	51.6	120757	1410	0	1594	0	0	0	0	0	0	4830	126997	7.6	8
Total / Av.	102854	1338354	2.92	0.995	51	52	778247	16920	0	10285	0	0	0	0	4886	0	31130	826297	7.6	8
Monthly Average	8571	7203	2.92	1	0	52	64854	1410	0	857	0	0	0	0	407	0	2594	68858	7.6	8
Daily Average	286	240	2.92	1	0	52	2162	47	0	29	0	0	0	0	14	0	86	2295	7.6	8

From the Energy Bill of FY 2021-22 it is observed that average monthly energy consumed was 8571 kWh with average power factor of 0.99.

However in the energy bill of the month of April, July, August 2021 and March 2022, recorded power factor was very low (e.g. power factor of 0.021 in the month of April 2021). It may be because of faulty reading of the meter.

Figure 1: Trend of MD of CUTM, Balangir



3.2 Base Line Energy Consumption and Specific Energy Consumption

During our audit it is seen that the load drawl pattern of CUTM, Balangir is typical of a unit functioning in day time but the Hostels are functioning beyond office hours. At night time minimum illumination inside the building and full outside lighting with street-lights are maintained. The office working hours in CUTM, Balangir is from 9AM to 6PM normally for 350 days in a year. During the office period normal loads are room lighting, fans, ACs and office appliances. During the entire office working hours the load remains steady with small variations.

Connected load details & corresponding kW consumption

From the inventory survey, it is estimated that there is a connected load of about 81 kW in CUTM, Balangir. It may be seen that the lighting load constitutes about 9% of the total load, the Fan load constitutes about 37% of the total load, the other load constitutes about 8% of the total load and air conditioning loads share about 46% of the total connected load. The following table indicates the estimated connected load details.

Table: Connected load details & corresponding kW

Summary of Electrical Load		
Load Centre	Kilowatt	Load in %
Lighting	7.461	9.26
Fan	29.85	37.07
AC	37.26	46.27
Other Load	5.96	7.40
Total	80.531	100

Figure 2: Pie Chart of Connected Load Details




Table: Detailed lighting inventory of all the units of CUTM, Balangir

Lighting Inventory				
Area Name	Types of Load	Wattage of each load in Watt	Nos. installed	Total connected Wattage in Watt
Ground Floor Public School Classroom	Tube Light	36	37	1332
	LED	9	6	54
First Floor Public School classrooms Tube light	Tube light	36	108	3888
First Floor Corridor Public School Tube light	Tube light	36	2	72
	LED	9	6	54
Second Floor Public School Classroom	Tube light	36	38	1368
	LED	9	6	54
Boys Canteen	Tube light	36	17	612
	LED	9	3	27
CUTM Main Building Ground Floor	LED bulb	9	4	36
	LED Tube light	20	12	240
	Fluorescent Light	36	101	3636
CUTM Main Building First Floor	LED bulb	9	3	27
	LED Tube light	20	8	160
	Fluorescent Light	36	112	4032
CUTM Main Building Second Floor	LED bulb	9	1	9
	LED Tube light	20	83	1660
	Fluorescent Light	36	71	2556
Total			618	7461

Table: Detailed inventory of ACs

AC inventory				
Area Name	Types of Load	Wattage of each load in Watt	Nos. installed	Total connected Wattage in Watt
Public School First Floor	Split AC	1500	17	25500
CUTM Ground floor	Split AC	1470	4	5880
CUTM First Floor	Split AC	1470	3	4410
CUTM Second Floor	Split AC	1470	1	1470
Total			25	37260

Table: Detail Inventory of all Types of Fan

Fan Inventory				
Sl. No.	Building Name	Wattage	Quantity	Total connected Wattage in Watt
1	Ground Floor Public School	75	37	2775
2	First Floor	75	89	6675
3	Second Floor	75	36	2700
4	Boys Canteen	75	10	750
5	CUTM Main Building Ground Floor	75	72	5400
6	CUTM Main Building First Floor	75	73	5475
7	CUTM Main Building Second floor	75	81	6075
Total			398	29850

Table: Detail inventory of other appliances

Other appliances inventory				
Area Name	Types of Load	Wattage of each load in Watt	Nos. installed	Total connected Wattage in Watt
Public School Ground Floor	CCTV	15	16	240
Ground Floor Corridor	CCTV	15	8	120
	Computer	125	2	250
First Floor	CCTV	15	16	240
First Floor Corridor	CCTV	15	9	135
Second Floor	CCTV	15	7	105
Second Floor Corridor	CCTV	15	4	60
Boys Canteen	Cooler	150	2	300

	CCTV	15	2	30
CUTM Main Building Ground Floor	Printer	10	0	0
	Cooler	150	0	0
	Projector	150	0	0
	CCTV	15	20	300
	PC	200	4	800
CUTM Main Building First Floor	Projector	150	1	150
	Cooler	150	2	300
	CCTV	15	22	330
	PC	200	13	2600
CUTM Main Building Second Floor	Projector	150	2	300
	Fridge	125	1	125
	Cooler	150	1	150
	PC	200	1	200
	CCTV	15	21	315
Total			128	5960

Energy saving Opportunity:

It is recommended to keep the monitors of the computers in standby mode rather in screen saver mode to reduce the power consumption of the computers when not in use. It is difficult to quantify the saving on account of this measure. The investment will be zero and simple payback period will be immediate.

3.3 Electrical Distribution System and Water Distribution System

The Power Supply system of CUTM, Balangir was studied and based on the observations; the single Line Diagram of existing Electrical distribution system of CUTM is drawn and furnished below.

Figure 3: Electrical Distribution System for 11/0.415 kV Transformer





Figure 4: Water Distribution System



3.4 Transformer Details

The technical specification of transformer and its % loading is furnished below:

Table: Technical Specification of Transformer

Particulars	TRF 100kVA
Make	Bidyut Transformers
Transformer rated in kVA	100.00
Rated voltage ratio in kV	11/0.433
Rated current ratio in Amp	5.25/133.33
No. of phase	3.00
Vector diagram	Dyn-11
Type of cooling	ONAN

The power measurement of transformer was carried out by 3 phase power analyzer. The results are attached in Annexure. Based on Average Power measurement data the transformer loadings and efficiency are calculated and furnished below.

Table: Transformer Performance Assessment

Technical data sheet of CUTM, Balangir Transformers	
Particulars	TRF 100kVA
Make	Bidyut Transformers
Transformer rated in kVA	100.00
Rated voltage ratio in kV	11/0.433
Rated current ratio in Amp	5.25/133.33
No. of phase	3
Vector diagram	Dyn-11
Type of cooling	ONAN
Measured voltage at LT side in kV	0.42
Measured current LT Side in Amp	52.23
Measured Power Factor	0.99
No Load Loss (kW)	0.32
Full Load Loss of Transformer (kW)	1.95

Measured load (kVA)	38.18
% Loading on the Transformer (Measured kVA/ Rated kVA)	38.18
Actual Losses of Transformer (kW)	0.60
Total Actual Power Delivered by Transformer in kW	37.79
Transformer Efficiency, %	98.43%
Transformer performance	Satisfactory

Power measurement was carried out at various outgoing cable emanating from the distribution board of each transformer and the results are tabulated below.

3.5 Study of Voltage, Current, Power Factor Profile

Trend of Output voltage profile, Current profile, Output Power profile, Power Factor profile, Voltage unbalance of Load Distributions furnished below.

Table: Voltage Variation and % Unbalance of Load Distribution

POWER									
SL. No.	Area	Incoming/Outgoing	Phase	Voltage in (V)	Current in (A)	PF	kW	Unbalance Voltage (V) in %	Unbalance Current (I) in %
1	Main Building Sec-2	Outgoing	R	235.2	12.3	0.99	14.93	0.03%	87.31%
			Y	235.3	24.6	0.9			
			B	235.2	2.5	0.9			
2	Centurion Public School Section-1	Outgoing	R	235.2	2.3	0.9	8.69	0.03%	106.33%
			Y	235.3	16.3	0.9			
			B	235.2	5.1	0.9			
3	Centurion Public School Section-2	Outgoing	R	235.2	26.1	0.9	19.62	0.03%	100.00%
			Y	235.3	27.4	0.9			
			B	235.3	0	0.9			

Observation

During the audit, high current unbalance was found in the Main Building Sec 2 and Centurion Public School Section 1, Section 2. The measured current unbalance is beyond the permissible level. The effects of unbalanced load are increased heat, reduced lifetime of machine, increased power losses, unreliable motor drives. Therefore it is recommended to have balanced load in all the three phases for efficient performance.

Table: Voltage Variation and %Unbalance of 100 kVA Transformer- CUTM

Voltage Variation and %Unbalance of 100 kVA Transformer- CUTM, Balangir						
Date	Time	Frequency	Phase-1 RMS	Phase-2 RMS	Phase-3 RMS	Vunb
		Hz	V	V	V	%
7/21/22	12:10:00 PM	49.99	424.8	427.8	421.4	0.8
7/21/22	12:10:05 PM	49.99	424.5	428	421.3	0.8
7/21/22	12:10:10 PM	50	424.4	428.3	421.3	0.9
7/21/22	12:10:15 PM	50	424.4	428.3	421.3	0.9
7/21/22	12:10:20 PM	50	424.4	428.1	421	0.9
7/21/22	12:10:25 PM	50	424.5	428.1	421.2	0.9
7/21/22	12:10:30 PM	50	424.4	428.1	421.1	0.9
7/21/22	12:10:35 PM	50.01	424.3	428.2	420.7	0.9
7/21/22	12:10:40 PM	50.02	424.2	428.3	420.5	1
7/21/22	12:10:45 PM	50.02	424	428.4	420.4	1
Average Voltage & %Unbalance			424.53			0.9

Figure 5: Trend of Voltage Variation and %Unbalance of 100 kVA Transformer- CUTM




Table: Current Variation and %Unbalance of 100 kVA Transformer- CUTM

Current Variation and %Unbalance of 100 kVA Transformer -CUTM						
Date	Time	Frequency	A1 RMS	A2 RMS	A3 RMS	Aunb
		Hz	A	A	A	%
7/21/2022	12:10:00 PM	49.99	48.6	41.3	58.2	14
7/21/2022	12:10:05 PM	49.99	48.5	41.2	58.1	14
7/21/2022	12:10:10 PM	50	48.6	41.5	58.1	13
7/21/2022	12:10:15 PM	50	48.7	41.5	58.2	13
7/21/2022	12:10:20 PM	50	48.7	41.5	58	13
7/21/2022	12:10:25 PM	50	48.6	41.4	58	13
7/21/2022	12:10:30 PM	50	48.6	41.5	57.6	13
7/21/2022	12:10:35 PM	50.01	48.3	41.4	57.6	13
7/21/2022	12:10:40 PM	50.02	48	41.4	57.6	13
7/21/2022	12:10:45 PM	50.02	48	41.5	57.6	13
Average Current & %Unbalance			49.72			13.2

Figure 6: Trend of Current Variation and %Unbalance of 100kVA Transformer- CUTM





Table: Average Power Factor of 100 kVA Transformer –CUTM

Average Power Factor of 100 kVA Transformer -CUTM						
Date	Time	Frequency	PF1	PF2	PF3	PF Mean
		Hz	Ph-1	Ph-2	Ph-3	Avg.
7/21/2022	12:10:00 PM	49.99	0.99	1	0.99	0.99
7/21/2022	12:10:05 PM	49.99	0.99	1	0.99	0.99
7/21/2022	12:10:10 PM	50	0.99	1	0.99	0.99
7/21/2022	12:10:15 PM	50	0.99	1	0.99	0.99
7/21/2022	12:10:20 PM	50	0.99	1	0.99	0.99
7/21/2022	12:10:25 PM	50	0.99	1	0.99	0.99
7/21/2022	12:10:30 PM	50	0.99	1	0.99	0.99
7/21/2022	12:10:35 PM	50.01	0.99	1	0.99	0.99
7/21/2022	12:10:40 PM	50.02	0.99	1	0.99	0.99
7/21/2022	12:10:45 PM	50.02	0.99	1	0.99	0.99
Average Power Factor						0.99

Table: Snapshot of Load in (W & VA) of 100 kVA Transformer-CUTM

Snapshot of Load in (W & VA) of 100 kVA Transformer-CUTM				
Date	Time	Frequency	Watt Total	Volt Amp Total
		Hz	W	VA
7/21/2022	12:10:00 PM	49.99	35997.4	36298
7/21/2022	12:10:05 PM	49.99	35981.1	36286
7/21/2022	12:10:10 PM	50	36055.5	36355
7/21/2022	12:10:15 PM	50	36044.8	36344
7/21/2022	12:10:20 PM	50	36012.8	36313
7/21/2022	12:10:25 PM	50	36006.8	36310
7/21/2022	12:10:30 PM	50	35895.7	36195
7/21/2022	12:10:35 PM	50.01	35788.1	36091
7/21/2022	12:10:40 PM	50.02	35738.7	36037
7/21/2022	12:10:45 PM	50.02	35741.4	36036
Average			35926	36227

Figure 7: Trend of Load & VA of 100 kVA Transformer-CUTM



4.0 LIGHTING SYSTEM

4.1 Lighting Inventory

Adequate and proper lighting contributes both directly and indirectly towards productivity and safety, and towards providing an improved work atmosphere. In fact, all these are inter-related and complimentary to each other. There are several factors, which contribute towards proper lighting. However, all efforts were made to study and include these factors during audit of CUTM for lighting loads.

To study, analyze and identify energy conservation options in lighting, a study of the building lighting load was conducted. The purpose of the study was to determine the lighting load and its distribution in various sections of the Building, determine the quality of illumination provided, and recommend measures to improve illumination and reduce electricity consumption.

A high quality and accurate digital LUX meter was used to measure the illumination level at various sections of the building during working hours. Other performance indicators such as type of lamps used, type of luminaries, physical condition of lamps and luminaries, use of day lighting, etc. was also noted down.

During the study, measurement of lighting loads, voltage conditions in the facility areas were carried out. The illumination level was also measured primarily at various classrooms and common areas of the building. Care was taken to reduce the effect of day

lighting while taking the measurements. The recorded inventory is enclosed in tabular form.

To determine the quantity of lighting load a physical count of the light fittings in CUTM, Balangir was carried out. Further, the inputs from the officials and maintenance log books were taken into consideration for calculating the inventory of total light fittings of the CUTM. The total connected load of lighting in CUTM is about 19.817kW. The summarized lighting installations are furnished below.

Table: Total individual lighting calculation of CUTM, Balangir

Lighting Inventory				
Area Name	Types of Load	Wattage of each load in Watt	Nos. installed	Total connected Wattage in Watt
Ground Floor Public School Classroom	Tube Light	36	37	1332
	LED	9	6	54
First Floor Public School class rooms Tube light	Tube light	36	108	3888
First Floor Corridor Public School Tube light	Tube light	36	2	72
	LED	9	6	54
Second Floor Public School Classroom	Tube light	36	38	1368
	LED	9	6	54
Boys Canteen	Tube light	36	17	612
	LED	9	3	27
CUTM Main Building Ground Floor	LED bulb	9	4	36
	LED Tube light	20	12	240
	Fluorescent Light	36	101	3636
CUTM Main Building First Floor	LED bulb	9	3	27
	LED Tube light	20	8	160
	Fluorescent Light	36	112	4032
CUTM Main Building Second Floor	LED bulb	9	1	9
	LED Tube light	20	83	1660
	Fluorescent Light	36	71	2556
TOTAL				19817

4.2 ENCON option for lighting system

Background:

It is observed that there is a scope in energy conservation in lighting system by replacing 36W FL Tube Fittings with 20W LED Tube light. The annual energy saving will be 28051 kWh and financial saving will be around Rs. 1.68Lakh & investment required will be Rs.1.77 Lakh with simple payback period of 1.1 Year.

Cost Benefit Analysis:

Cost Benefit Analysis for Replacement of 36W FL Tube Fittings with 20 W LED Tube light		
Particulars	Unit	Value
Total no. of 36 W FL Tube Fittings	Nos.	487
Total no. of 20W LED Tube Fittings Required	Nos.	487
Present Lighting Load	kW	18
Future Lighting Load after Implementation	kW	9.74
Saving in Load	kW	7.792
Run Hour/day	hr	12
Annual Energy Saving	kWh	28051
Annual Energy Saving	TOE	2.4
Annual Cost of Savings @ Rs.6/unit	Rs.	168307
Investment Required	Rs.	177268
Simple Payback Period	Year	1.1

Background:

It is observed that there is a scope in energy conservation in lighting system by Installation Light pipe Fitting System. By using light pipe system the annual energy saving will 8448 kWh and financial saving will be around Rs.0.49 Lakh & investment required will be Rs. 1.15 Lakh with simple payback period of 2.3 Years.

Cost Benefit Analysis Installation Light pipe Fitting System at CUTM, Balangir		
Particulars	Unit	Value
Total Nos. of Rooms in Boys Hostel Top Floor	Nos.	20
Operating Hour	Hours	8
Avoidance of expected Lighting Load per Annum	kW	3.2
Nos. of Light Pipe System to be Installed	No.	10

Annual Energy Saving @330 Days	kWh	8448
Annual Energy Saving	TOE	0.73
Annual Financial Saving	Rs. in Lakh	0.49
Investment Required	Rs. in Lakh	1.15
Simple Payback Period	Year	2.3

Background:

There is a scope in energy conservation in lighting system by Light Motion Sensor at Boys Canteen. By using motion sensor, the annual energy saving will 345 kWh and financial saving will be around Rs. 2019 & investment required will be Rs. 4248 with simple payback period of 2.1 Years.

Cost Benefit Analysis for Installation of Light Motion Sensor at Boys Canteen		
Particulars	Unit	Value
Total no. of existing 36 W LED fitting	Nos.	17
Total no. of existing 9 W LED fitting	Nos.	3
Present Lighting Load in Boys Canteen	kW	0.64
Future Lighting Load After installation motion sensor considering @15% saving	kW	0.5
Saving in Load	kW	0.1
Run Hour/day	hr	12
Annual Energy Saving	kWh	345
Annual Energy Saving	TOE	0.03
Annual Cost of Savings @ Rs. 6/unit	Rs.	2019
Investment Required	Rs.	4248
Simple Payback Period	Year	2.10

4.3 O & M Practice, Energy Accounting and Monitoring For Lighting System

CUTM electrical maintenance team looks after the operation & maintenance of electric supply, ventilation & air conditioning, lighting system etc. The works involves maintenance of Lighting system, Light replacement, Switching on/off of street light. Solar Street light system installed and maintained by CUTM technicians. But now a days, the timers are available and the street lights are operated automatically. It is observed that there is no proper document available for keeping the records of lighting maintenance, LUX survey, lighting inventory list, area wise lighting consumption etc. A set of well designed format for lighting system record keeping may be developed and maintained at the earliest.

Proper lighting inventory list to be maintained, further during any replacement of lighting system, same may be simultaneously updated in the inventory.

The Monitoring and Targeting programs have been so effective that they show typical reductions in annual energy costs between 5% and 20%.

The essential elements of M&T system are

- Recording: Measuring and recording energy consumption.
- Analyzing: Correlating energy consumption to actual energy consumption
- Comparing: Comparing energy consumption to an appropriate standard or benchmark.
- Setting Targets: Setting targets to reduce or control energy consumption.
- Monitoring: Comparing energy consumption to the set target on a regular basis.
- Reporting: Reporting the results including any variances from the targets which have been set.
- Controlling: Implementing management measures to correct any variances, which may have occurred.

4.4 Illumination Survey and LUX Level Measurement

The Illumination survey of the CUTM Building including Corridor were carried out by measuring the LUX of the different area, Lab, Office Room, Auditorium, Street Light and Class Room using LUX meter and the results are tabulated below.

Table: LUX Measurement

LUX Measurement		
Area	Measured LUX	Recommended LUX
Library	75,80	200-300-500
Office Room	75,80,90	50-100-150
Street Lights	35,45	50-100-150
Class Room	50,55,65,70	200-300-500

It was observed that LUX level of street lights at different location are at average illumination, also there is rare occupancy & less movement in the street light area during night time, so the LUX level is not causing any difficulties.

It is suggested to conduct periodic LUX level survey (preferably once in 3 months) and maintain record properly. Necessary corrective actions should be taken periodically.

Awareness among staff, student and control room operators is to be created for improvement in all aspects of energy conservation especially relating to lighting in their respective wings.

4.5 ENCON Option for Installation of Solar Water Heater

It is recommended that after installation of Solar Water Heater of 500 LPD, the annual LPG saving @300days will be 630 Kg, annual cost saving will be Rs. 0.59 Lakh. Around Rs. 0.7 Lakh of investment will be required and payback period shall be 1.19 years.

Table: Cost Benefit Analysis of Installation of Solar Water Heater

Cost Benefit Analysis of Installation of Solar Water Heater at CUTM Canteen		
Particulars	Unit	Value
Hot Water for Canteen per Day by Solar Water Heater	LPD	500
Consumption of LPG for heating Water	Kg	2.10
Annual LPG Consumption for heating water	Kg	630
Annual Thermal Energy Saving	kCal	7247899
Annual Energy Saving	TOE	1
Annual expenditure due to LPG consumption for solar water heating @ 93.2/Kg	Rs.	58746
Installation Cost of 500 LPD Solar Water Heater	Rs.	70000
Annual financial saving due to reduction in LPG consumption	Rs. Lakh	0.59
Investment required	Rs. Lakh	0.70
Simple Payback Period	Year	1.19

4.6 ENCON Option for Installation of Solar Power Plant in Net Metering Concept

Concept of Net Metering:

Net metering is the concept which records net energy between export of generated energy and import of DISCOM energy for a billing month. Alternatively, the meter, having the feature of recording both the import and export values, also are generally allowed for arriving net energy for the billing period.

Principle of net metering:

Based on available roof area / ground area solar PV panels will be installed. The output of the panels (DC electricity) will be connected to the power conditioning unit / inverter which converts DC to AC. The inverter output will be connected to the control panel or distribution board of the building to utilize the power. The inverter synchronizes with grid and also with any backup power source to produce smooth power to power the loads with preference of consuming solar power first. If the solar power is more than the load requirement, the excess power is automatically fed to the grid. For larger capacity systems connection through step up transformer and switch yard will be used to feed the power to grid.

Advantages of net metering:

The grid connected roof top / ground mounted solar PV system would fulfill the partial / full power needs of large scale buildings. The following are some of the benefits of roof top SPV systems:

- Generation of environmentally clean energy
- Consumer becomes generator for his own electricity requirements
- Reduction in electricity consumption from the grid
- Reduction in diesel consumption wherever DG backup is provided
- Feeding excess power to the grid

It is recommended that after installation of Roof Top at CUTM, Balangir, the annual energy generation will be 99864 kWh, annual cost saving will be Rs. 6 Lakh. Around Rs. 30 Lakh of investments will be required and payback period shall be 5 years.

Table: Cost Benefit Analysis of Establishment of Solar Power Project in CUTM, Balangir

Installation of Roof top Solar Power Plant		
Units Generation	Unit	Value
Total Annual Energy Consumed from TPCODL in FY 2020-21	kWh	102854
Average Base Demand from TPCODL	kW	12
Proposed capacity of the Solar Power Project to be installed	kW	61.796
Total Area Required	Sq. ft.	7415.57
Total Area Available	Sq. ft.	18500
Maximum Solar Project feasible	kW	154
Proposed capacity of the Solar Power Project to be installed	kW	60
Total Project Cost Required	Rs. Lakh	30
Capacity Utilization Factor	%	0.19
Net Annual Generation	kWh	99864

Annual Energy Saving	TOE	8.59
Weighted Average Rate of Electricity	Rs./kWh	6
Annual Saving in Energy Bills due to Consumption from own solar power	Rs. Lakh	6
Simple Payback Period	Years	5.0

Installation of Roof top Solar Power Plant		
Units Generation	Unit	Value
Total Annual Energy Consumed from TPCODL in FY 2020-21	kWh	102854
Average Base Demand from TPCODL	kW	12
Proposed capacity of the Solar Power Project to be installed	kW	61.796
Total Area Required	Sq. ft.	7415.57
Total Area Available	Sq. ft.	18500
Maximum Solar Project feasible	kW	154
Proposed capacity of the Solar Power Project to be installed	kW	60
Total Project Cost Required	Rs. Lakh	30
Capacity Utilization Factor	%	0.19
Net Annual Generation	kWh	99864
Annual Energy Saving	TOE	8.59
Weighted Average Rate of Electricity	Rs./kWh	6
Annual Saving in Energy Bills due to Consumption from own solar power	Rs. Lakh	6
Simple Payback Period	Years	5.0

Implementation:

1. The total project cost to be borne by the consumer, however consumer is eligible for any subsidy / grant from State Govt. / Central Govt. / MNRE as applicable from time to time Implementation of net metering facility shall be made applicable for the consumers having 3-phase supply service connection.
2. Protection system including its switch gear to be certified by concerned Ex. Engineer and harmonic suppressive device to be installed by such SPV generator to suppress the harmonics injection as harmonics is more in case of solar plants where conversion of DC to AC is taking place. Islanding protection requirements to be provided.
3. The SPV generator shall provide the indication of solar PV plant at the injection point for easy identification to the operating personnel.
4. The SPV generator needs to get statutory approvals from appropriate authority like Electrical Inspector for the connected equipment including its solar panels.
5. The proposed generator shall submit the prescribed application to the concerned Executive Engineer of local DISCOM who should be nodal authority for approval of the same.

5. The net meter / meter to be used for arriving net energy shall have the specifications prescribed.
6. Concerned JE of DISCOM shall issue a technical feasibility certificate and witness the synchronization of SPV plant with distribution network.
7. 0.5 class accuracy, tri-vector based energy meter, non ABT having the MRI downloading facility along with related accessories shall have to be installed by the SPV generator as per the specifications of DISCOM.
8. Spot billing is to be arranged by concerned DISCOM as per the billing period. DISCOM shall arrange to develop suitable software and incorporate in the billing instrument for such billing.

It is recommended to install 60 kW Solar Project in CUTM, Balangir.

5.0 HVAC System

At present, the air conditioning system in the CUTM is met through window /split AC of following number. There are around 25 numbers air conditioning systems in CUTM, Balangir.

It is estimated that there is about 37 kW of AC load in CUTM contributing to about 46% of the total connected load.

Installed Air conditioning System of CUTM are furnished below:

Table: Detail Inventory of ACs of CUTM, Balangir

AC Inventory				
Area Name	Types of Load	Wattage of each load in Watt	Nos. installed	Total connected Wattage in Watt
Public School First Floor	Split AC	1500	17	25500
CUTM Ground floor	Split AC	1470	4	5880
CUTM First Floor	Split AC	1470	3	4410
CUTM Second Floor	Split AC	1470	1	1470
Total			25	37260

5.1. ENCON Option for Installation of AC Saver for old 1.5 Ton AC

It is observed that there is a scope in energy conservation in AC system by Installation AC Saver for old 1.5 Ton AC. By using AC Saver, the annual energy saving will be 23693 kWh and financial saving will be around Rs. 1.4 Lakh & investment required will be Rs. 2 Lakh with simple payback period of 1.4 Years.

Cost Benefit Analysis for Installation of AC Saver for Old 1.5 Ton AC		
Particular	Unit	Value
Present nos. of 1.5 Ton AC	Nos.	25
Total Capacity	TR	37.5
Av. Electrical Load of each existing AC before Replacement	kW	1.755
Total Av. Electrical Load before Replacement	kW	43.875
Annual Energy consumption before implementation	kWh	157950
Annual Energy consumption after implementation of AC Saver assuming @15% saving	kWh	134258
Annual Energy Saving due to Installation of AC Saver	kWh	23693
Annual Energy Saving	TOE	2.04
Annual Cost of Savings @ Rs.6.0/unit	Rs. Lakh	1.4
Investment required	Rs. Lakh	2.0
Simple payback period	Years	1.4

Table: EESL-SEAC BOQ (Voltas)

EESL-SEAC BOQ (Voltas)		
Sl.No.	Descriptions of Item	
1	Supply of 1.5 TR split inverter AC, Rated ISEER 5.4. energy efficient 5 Star AC. (indoor unit, outdoor unit, remote control)	1 No.s
a	Refrigeration Piping(Copper) for 1.5 TR Hi wall Unit- (RMT)	3
b	Electrical Cable - (RMT)	3
c	Drain Pipe - (RMT)	3
2	No of Preventive Maintenance Service in a Year	2



Star Rating	Stars	5
Cooling Capacity Full Load (100%)	W	5280
Cooling Capacity Half Load (50%)	W	2640
Cooling Power Full Load	W	1310

(100%)			
Cooling Power Half Load (50%)		W	433
ISEER			5.4
Power Supply		V/Hz/Ph	230 / 50 / 1 Phase
Air Flow Volume - Indoor		CMH	950
*Noise Level - Indoor		..dB(A)	≤46
Operation			LCD Remote
Compressor Type			High EER Twin Rotary - BLDC
Wide Operating Voltage Range		V	145~270
Max operating Ambient Temp Range		Deg C	52 ^o C
Refrigerant Gas			R32
Indoor Unit Dimension (WxHxD)		mm	990x315x242
Indoor Unit Net / Gross Weight		Kg	13.5/16.5
Outdoor Unit Dimension (WxHxD)		mm	870x600x355
Outdoor Unit Net / Gross Weight		Kg	33.5/39
Connecting Pipe		type	Cu-Cu(12.5mm & 6.35mm)
Connecting Pipe Length		Meter	3.0
Connecting Cable		Meter	3.0
Condenser Coil			Fin & Tube
No of boxes		ODU	1 Box
		Connecting Tube	
		IDU	1 Box
Features	Filter	Anti Dust	Yes
		Catechin Filter	Yes
		Acaro Bacterium	Yes
		Silver Ion	Yes
	IDU Fin	HydrophilicAluminum	Blue
	Copper tubes	Inner Grooved	Yes
	IDU	LED Display	Yes
		Self Diagnosis	Yes
		Anti Fungal	Yes
		5D Concept	Yes

		Auto Restart	Yes
	Remote	Sleep Mode	Yes
		Turbo	Yes
		Swing	Yes
		LCD Remote	Yes
		Lock	Yes
		Timer	Yes
		Glow Buttons	Yes
		Dual Temp Display	Yes
	Air Vent	Cross Flow	Yes
* Noise level reflects the levels in Anechoic Chamber			
All above performance data are as per IS 1391 Rated conditions.			
No Derating in cooling capacity at 43 degree Celsius.			
	Cost per AC (For Consumer) in INR - (1 Year Comprehensive Warranty & 5 Year Warranty on Compressor)		39990
	Miscellaneous Cost		Voltas
1	Additional warranty for one year i.e. for 2nd year post the expiry of the standard one year warranty ; inclusive of GST	Unit	2200
2	Additional warranty for one year i.e. for 3rd year post the expiry of the standard one year warranty ;inclusive of GST	Unit	2400
3	Copper Pipe ; inclusive of GST	Per Meter	600
4	EPPDM Rubber Insulation for refrigerant piping ; inclusive of GST	Per Meter	90
5	Power Cable ; inclusive of GST	Per Meter	120
6	Drain Pipe ; inclusive of GST	Meter	100
7	Buyback of old Acs ; inclusive of GST	Unit	2500
8	Additional warranty for 4 year (Inclusive of GST)		4000

5.2 Advantages of Inverter Air Conditioner

The latest and the most efficient technology that is available in market today is the Inverter Technology for air conditioners. Inverter technology is designed in such a way that it can save 30-50% of electricity (units consumed) over a regular air conditioner.

Inverter air conditioners are more powerful, offer great savings and are better at maintaining temperature compared to non-inverter air conditioners. When compressor needs more power, it gives it more power. When it needs less power, it gives less power. With this technology, the compressor is always on, but draws less power or more power

depending on the temperature of the incoming air and the level set in the thermostat. The speed and power of the compressor is adjusted appropriately.

Let's take an example of 1.5 Ton inverter air conditioner versus non-inverter air conditioner

A 1.5 Ton inverter air conditioner works initially at 1.7 Ton and as the desired temperature is achieved it reduces its capacity to 1.5, 1 or 0.3 Ton based on room conditions.

A 1.5 Ton non-inverter air conditioner on the other hand works at 1.5 Ton all the times.

Every air conditioner is designed for a maximum peak load. So a 1.5 ton AC is designed for a certain size of room and 1 ton AC for a different size. But not all rooms are of same size. A regular air conditioner of 1.5ton capacity will always run at peak power requirement when the compressor is running. An air conditioner with inverter technology will run continuously but will draw only that much power that is required to keep the temperature stable at the level desired. So it automatically adjusts its capacity based on the requirement of the room it is cooling. Thus, drawing much less power and consuming lesser units of electricity.

5.3 Maintenance Tips for Split / Window AC

- Make sure AC doesn't get overloaded; check the fuse or circuit breaker if it doesn't operate.
- Remember to replace or clean the filter and have your mechanic clean the evaporator and condenser coils regularly, for the air conditioner to cool the home efficiently.
- Install a programmable thermostat, it will lead to 10-15% energy saving.
- Set the thermostat as high as possible comfortable.
- Set the fan speed on high except on very humid days, when humidity is high set the fan speed on low for more comfort.
- Install units in shade, it will lead to 10% saving in energy consumption.
- Use sun films on windows. That will cut heat entry by 70% of the building.
- If the AC makes noise it needs to be checked by the mechanic
- A good air filter will extend the life of the air conditioner because the important parts, like the cooling coil, and other inner parts will stay cleaner, operate more efficiently and last longer.
- Avoid frequent opening of doors/windows. A door kept open can result in doubling the power consumption of your AC.
- Ensure direct sunlight (and heat) do not enter the air-conditioned space, particularly in the afternoons.
- Most people believe that a thermostat set to a lower temperature than desired, will force air-conditioner to cool faster, not really, all it does, is make air-conditioner

operate for longer. Moreover, it will result in unnecessarily chilly room and wasted power. Every degree lower on the temperature setting results in an extra 3-4% of power consumed. Hence, once a comfortable temperature found then set the thermostat at that level, avoid touching the thermostat thereafter.

- Once an air-conditioning system has been designed and installed avoid any major change in the heat-load on the AC. This will add to wasted power.
- Always ensure that whenever new unit is installed, make sure its EER (12/ (kW/TR)) should be between 9.5 to 10.5.
- No gap should be left during installing units for cool air escape.

6.0 Fan Inventory

At present, there are 398 nos. of ceiling fans are available in CUTM campus and it is estimated that there is about 30 kW of Fan load in CUTM contributing to about 37 % of the total connected load.

Table: Fan Inventory

Fan Inventory				
Sl. No.	Building Name	Wattage	Quantity	Total connected Wattage in Watt
1	Ground Floor Public School	75	37	2775
2	First Floor	75	89	6675
3	Second Floor	75	36	2700
4	Boys Canteen	75	10	750
5	CUTM Main Building Ground Floor	75	72	5400
6	CUTM Main Building First Floor	75	73	5475
7	CUTM Main Building Second floor	75	81	6075
Total			398	29850

Energy Conservation Option

It is observed that there is a scope in energy conservation in fan system by replacing Conventional Ceiling Fan with 26W Energy Super Efficient Fan. By using recommended fan the annual energy saving will 54605.6kWh and financial saving will be around Rs.3.27Lakh & investment required will be Rs. 11.26 Lakh with simple payback period of 3.4Years.

Table: Cost Benefit Analysis of Fan

Cost Benefit Analysis for replacing Conventional Ceiling Fan 75W with Super Energy Efficient Ceiling Fan		
Total No. of Fans Operating	Nos.	398
Present Load before Replacement @ 75W per Fan	kW	29.9
Load after Replacement @ 26 W Energy Efficient Super Fan	kW	10.3
Saving in Load	kW	19.5
Run hour /Day	hr	8
Annual Energy Saving Assuming 350 Days	kWh	54605.6
Annual Energy Saving	TOE	4.7
Annual Cost of Savings @ Rs. 6/unit	Rs.	327634
Total Investment Required	Rs.	1126738
Simple Payback Period	Years	3.4

7.0 DIESEL GENERATING (DG) SET

7.1 Observation & Analysis for DG Set

- There is one no. of DG set of 62.5 KVA capacity installed in CUTM to meet the power requirement of the major areas of the building in case of power supply failure from TPWODL.
- The technical specification of the DG Set is furnished below:

Table: Technical specification of the DG set

Technical Specification of DG	
Particulars	DG Set 1
Make	Western Consolidated Private Ltd.
Capacity in kVA	62.5
Phase	3
Rated Voltage in Volt	415
Rated PF	0.8
Rated Speed in RPM	1500
Date of Mfg	12/05/2015
Rated Fuel Consumed in Litre/Hour	1/144

Diesel Consumption of 62.5 kVA DG Set for FY 2021-22 is furnished below:

Table: Diesel Consumption of 62.5 kVA DG Set for FY 2021-22

Month	Diesel Consumption in KL
Apr-21	0.050
May-21	0.050
Jun-21	0.050
Jul-21	0.050
Aug-21	0.050
Sep-21	0.050
Oct-21	0.050
Nov-21	0.050
Dec-21	0.050
Jan-22	0.050
Feb-22	0.050
Mar-22	0.050
Total	0.60

7.2 Recommendation

- The DG set is normally operated in power failure condition and in any emergency load requirement case.
- The details of energy generated and consumption of Diesel for the DG set is not being recorded presently for which the specific energy consumption of DG set could not be evaluated.
- So it is recommended that the DG set generation and HSD consumption details are to be noted monthly basis in log book for future reference and evaluation of SEC.
- The DG set should be inspected by Electrical Inspector; Energy Meter should be installed across the DG set and sealed properly in consultation with Chief Electrical Inspector.
- The record of energy generated in DG set is not available. It is to be recommended that energy meter is to be installed in each DG set and the energy generated in each DG set has to be recorded to calculate the specific energy consumption of DG set.

8.0 TRANSPORTATION

It is observed that the University has 16 numbers of vehicles consisting of 7 numbers of bus, 9 numbers of four wheelers. The list of the vehicles is mentioned below.

Table: Vehicle Detail of CUTM, Balangir

CUTM , Balangir Vehicle Details		
Vehicle Type	What is this used for	Number of vehicles
Bus	College	7
Winger	Office & Guest	3
Magic Van	College	2
Food Van	College	2
Light Vehicle	Office & Guest	2

Recommendation:

It is recommended that either replace the lower efficiency vehicles with Electric Vehicles or they may be operated for smaller distances.

9.0 WATER PUMPING SYSTEMS**9.1 Water Pumping Storage and Distribution System**

CUTM meets its water requirement from Ground water through sump storage facility, the pump motors is having various connections like both single and 3-phase connection.

9.2 Utilization of water Pumping System

There are submersible types of pumps installed in CUTM for the auxiliary consumption of water like housekeeping, gardening etc. There are 3 nos. of 1.5HP submersible pumps and 2nos. of 1 HP pumps.

There are submersible types of pumps installed in CUTM for the auxiliary consumption of water like housekeeping, gardening etc. Since, these are submersible type pump, therefore the study mechanical power system could not be carried out and no recommendation is furnished for the same. It is recommended that in future flow meter to be installed and water consumption to be monitored.

9.3 Rain Water Harvesting System

The rainwater harvesting system is one of the best methods practiced and followed to support the conservation of water. Today, scarcity of good quality water has become a significant cause of concern. It is recommended that RWH system may be installed for water conservation.

9.4 Sewage Treatment Plant

The campus has no sewage treatment plants for the primary treatment and management of sewage generated in the campus including its hostel and residential area. It is recommended to install sewage treatment plant so that the treated water can be used for gardening purposes inside the campus. The use of treated water will reduce the ground water use and additionally the treated sludge will be very useful increasing the fertility of the soil.

9.5 Operation and Maintenance of CUTM

CUTM Electrical Maintenance team looks after the operation & maintenance of electric supply, ventilation & air conditioning, lighting system etc. of the entire building to ensure proper work environment and comfort of its residents and officials. There is one Electrician working in CUTM. The work involves maintenance of lift, AC, motor, normal Fuse call Attending, Light replacement, Switching on/off of street light.

9.6 Energy Monitoring & Accounting System

Energy monitoring and targeting (M & T) is primarily a management technique that uses energy information as a basis to eliminate waste, reduce and control current level of energy use and improve the existing operating procedures. It builds on the principle “you can’t manage what you don’t measure”. It essentially combines the principles of energy use and statistics.

While, monitoring is essentially aimed at establishing the existing pattern of energy consumption, targeting is the identification of energy consumption level which is desirable as a management goal to work towards energy conservation.

Monitoring and Targeting is a management technique in which building utilities such as fuel, refrigeration, water, effluent, and electricity are managed as controllable resources in the same way that inventory, building occupancy, personnel and capital are managed. It involves a systematic, disciplined division of the facility into Energy Cost Centers. The utilities used in each centre are closely monitored. Once this information is available on a regular basis, targets can be set, variances can be spotted and interpreted, and remedial actions can be taken and implemented.

The Monitoring and Targeting programs have been so effective that they show typical reductions in annual energy costs in various industrial sectors between 5 and 20%.

The essential elements of M&T system are:

- Recording: Measuring and recording energy consumption.

- Analyzing: Correlating energy consumption to actual energy consumption
- Comparing: Comparing energy consumption to an appropriate standard or benchmark.
- Setting Targets: Setting targets to reduce or control energy consumption.
- Monitoring: Comparing energy consumption to the set target on a regular basis.
- Reporting: Reporting the results including any variances from the targets which have been set.
- Controlling: Implementing management measures to correct any variances, which may have occurred.

The energy used by any business varies with production processes, volumes and input. Determining the relationship of energy use to key performance indicators will allow the Building owner to determine:

- Whether the current energy is better or worse than before
- Trends in energy consumption that reflects seasonal, weekly, and other operational parameters
- How the future energy use is likely to vary Specific areas of wasted energy
- Comparison with other business with similar characteristics - This “benchmarking” process will provide valuable indications

Electrical Safety:

It is observed that the Single Line Diagram (SLD) of the entire electrical system is to be displayed at concerned places. This will help in identifying the fault easily and doing the maintenance job more effectively. The SLD should be reviewed once in year to put necessary changes.

At Panel rooms, the following points are suggested as per safety & electricity rules.

- Rubber mats should be placed on the floor around the PDB panels in each switch room.
- No panel door should be kept open in both sides.
- Proper bunching of cables should be ensured at each switch room. The cables should be clearly tagged at starting & ending points which would help for easy the identification of cables for fault finding & maintenance work.
- Danger plates should be displayed at concerned places.
- Proper naming of loads should be done on each panel.

Awareness and attitude of occupants toward energy efficiency:

It is suggested to create energy conservation awareness among the staff by observing Energy Conservation Day, encouraging & recognizing energy conservation efforts made by any individual or groups. A core committee on Energy Conservation, Electrical Safety, and Resource conservation may also be formed to review the related activities.

10.0 TECHNICAL SPECIFICATIONS FOR ENERGY EFFICIENT PRODUCT

1. Capacitor Bank

Standard parameter	Value/Feature
Total rating of capacitors	40 kVAr
Rated AC Voltage	440Volt
Frequency	50 Hz
No. of Phases	3 phase
Standard	IS 13340-1993
APFC relay	Microprocessor Based
Losses	< 0.2 W/kVAr

2. Lighting

Standard Parameter	Feature
Voltage	220 - 240 V
Shape	Bulb
Lifetime of lamp	15000 hour(s)
Lumen maintenance factor	0.7
Average life (at 2.7 hrs/day)	15.2 year(s)
Number of switch cycles	50000
Rated luminous flux	1400 lm
Rated lifetime	15000 hour(s)
Rated beam angle	150 degree
Light output	1400 lumen
Beam angle	150 degree
Colour temperature	6500 K
Light effect/finish	Cool Daylight
Colour rendering index (CRI)	80
Starting time	<0.5 s
Warm-up time to 60% light	Instant full light
Colour	Cool Daylight

3. Air Conditioner

Standard Parameter	Feature
Split AC (1.5 Ton)	
Cooling Capacity (Watt)	5280
Max Power Consumption (Watt)	1310
Preferable BEE Star Rating	5
Energy Efficiency Ratio (EER)	5.41 W/W
Preferable Compressor Type	Rotary/reciprocating
Preferable Refrigerant Gas	R-32

4. Energy Efficient Fan

Model Name	E1-1200
Reversible Rotation	No
Remote	Yes
Blade Material	Aluminum
Leaf	3

Weight (kg)	4
Dimensions	120 x 140 cm
Down rod Height	30.48 cm
Span (mm/inch)	1200/48
Rated Voltage *	140 - 285
Rated Frequency	48 - 52
Input Power (typical)	26
Power Factor (typical)	0.95
Air Delivery	230

STAR RATING IN ROOM AIR CONDITIONERS

For Unitary Type Air Conditioner

(From 1st January, 2021 to 31st December, 2023)

Indian Seasonal Energy Efficiency Ratio (kWh/kWh)		
Star level	Minimum	Maximum
1 Star	2.7	2.89
2 Star	2.9	3.09
3 Star	3.1	3.29
4 Star	3.3	3.49
5 Star	3.5	

For Split Type Air Conditioner

(From 1st January, 2021 to 31st December, 2023)

Indian Seasonal Energy Efficiency Ratio (kWh/kWh)		
Star level	Minimum	Maximum
1 Star	3.3	3.49
2 Star	3.5	3.79
3 Star	3.8	4.39
4 Star	4.4	4.99
5 Star	5.0”;	

STAR RATING IN DISTRIBUTION TRANSFORMERS

Permissible Limit for Dry Type Transformers

Rating kVA	Max. Losses at 50% loading W*	Max. Losses at 100% loading W*	Max. Losses at 50% loading W*	Max. Losses at 100% loading W*
	Up to 22 kV class		33 kV class	
100	940	2400	1120	2400
160	1290	3300	1420	3300
200	1500	3800	1750	4000
250	1700	4320	1970	4600
315	2000	5040	2400	5400
400	2380	6040	2900	6800
500	2800	7250	3300	7800
630	3340	8820	3950	9200
800	3880	10240	4650	11400
1000	4500	12000	5300	12800
1250	5190	13870	6250	14500
1600	6320	16800	7500	18000
2000	7500	20000	8880	21400
2500	9250	24750	10750	26500

Permissible Limit for Oil Type Transformers

Rating (kVA)	Impedance (%)	Max. Total Loss (W)					
		BEE 1 Star		BEE 3 Star		BEE 5 Star	
		50 % Load	100% Load	50 % Load	100% Load	50 % Load	100% Load
16	4.5	135	440	108	364	87	301
25	4.5	190	635	158	541	128	448
63	4.5	340	1,140	270	956	219	791
100	4.5	475	1,650	392	1,365	317	1,130
160	4.5	670	1,950	513	1,547	416	1,281
200	4.5	780	2,300	603	1,911	488	1,582
250	4.5	980	2,930	864	2,488	761	2,113
315	4.5	1,025	3,100	890	2,440	772	1,920
400	4.5	1,225	3,450	1,080	3,214	951	2,994
500	4.5	1,510	4,300	1,354	3,909	1,215	3,554
630	4.5	1,860	5,300	1,637	4,438	1,441	3,717
1,000	5.0	2,790	7,700	2,460	6,364	2,170	5,259
1,250	5.0	3,300	9,200	3,142	7,670	2,991	6,394
1,600	6.25	4,200	11,800	3,753	10,821	3,353	9,924
2,000	6.25	5,050	15,000	4,543	13,254	4,088	11,711
2,500	6.25	6,150	18,500	5,660	16,554	5,209	14,813

STAR RATING IN PUMP SETS

Star Rating	Performance Factor of the Pump Set
1 Star	≥ 1.00 & < 1.10
2 Star	≥ 1.10 & < 1.20
3 Star	≥ 1.20 & < 1.30
4 Star	≥ 1.30 & < 1.40
5 Star	≥ 1.40

11.0 MOU Format with EESL

MEMORANDUM OF UNDERSTANDING

This Memorandum of Understanding ("MOU"), effective from _____ is to confirm discussions between Energy Efficiency Services Ltd (EESL), a company organized under the laws of India; with its corporate office at 5th & 6th Floor, Core-3, SCOPE Complex, 7-Lodhi Road, New Delhi-110003 and Centurion University of Technology & Management (CUTM) Behind Of BSNL Office, IDCO Land, Indira Nagar, Balangir, Odisha 767001.

Article 1: Purpose and Scope

This MOU confirms the preliminary discussions between CUTM and EESL regarding their intention to enter into transactions or services pertaining to implementation of energy efficiency measures at premises of CUTM.

A. Diagnostic Studies & Pilot Projects

- 1) Energy audits for entire campus to identify avenues for energy saving in electrical and thermal utilities
- 2) Water audits to identify areas/means to reduce specific water consumption
- 3) Lubricant and diesel Conservation Studies
- 4) Pilot studies on Cross-Cutting technologies

B. Implementation of Energy Efficiency Projects through innovative financial models

- 1) Installation/distribution of LED Lights and Energy Efficient appliances (Fans and / or Air Conditioners) across the facilities of CUTM.
- 2) Installation of energy efficient motors (IE3 type) in place of conventional motors
- 3) Installation of Smart Meters

4) Installation of Solar PV Power Projects

C. Capacity Building & Training

- 1) Technical training to campus executives on various topics pertaining to Energy Management, Maintenance Management, Water Management and Safety Engineering
- 2) Organizing suitable study tours and Guest Lectures on suitable topics
- 3) Creating cadre of energy professionals i.e. certified energy managers and auditors
- 4) Facilitating in Certification and Recognition: National Energy Conservation Award, Green Building etc.

EESL in consultation with CUTM shall execute the implementation of Energy Efficiency projects on ESCO Model (Energy Servicing Company). Under this activity, CUTM would provide the inventory list of their facilities / buildings and EESL would submit the Business and Financial proposal based on deemed savings principle leading to signing of Contract Agreements (s).

The activities are advisory services which EESL will provide with consultancy charges after mutual agreement between the Parties. EESL will submit proposals or annual work plans depending upon the requirement from CUTM.

Article 2: Non-Binding MOU for Future Cooperation

This MOU describes the general conditions and arrangements for further discussions between the parties and is non-obligatory. The exact terms and conditions of this future cooperation will be negotiated in due course and delineated in one or more separate and definitive agreements in the future, should circumstances warrant. Neither party shall be liable to the other for any claim, loss, cost, liability or investment opportunities arising out of directly or indirectly related to the other Party's decision to terminate this MOU, the other Party's performance under this MOU, or any other decision with respect to proceeding or not proceeding with the definitive agreement(s) or the Project(s). Further, each party acknowledges and agrees that the decision to enter into definitive agreement is the sole and absolute discretion of the other party.

Article 3: General Terms and Conditions

A) Term: This MOU shall remain in full force and effect for a period of thirty-six (36) months from the effective date, unless it is: (i) superseded by any or all of the definitive documents contemplated in Article 2 (or such other definitive documents as the parties may agree to enter into for their mutual benefit), or (ii) earlier terminated for convenience by the parties in writing by giving 30 (thirty) calendar days' notice.

B) Modification; Waiver; Severability; Assignment: No waiver of any right or remedy on one occasion by either party shall be deemed a waiver of such right or remedy on any other occasion, if any provision of this MOU is held invalid under any applicable law, such holding shall not affect the validity of remaining provisions and same shall continue in full

force and effect. Neither party may assign this MOU, in whole or in part, without the prior written consent of both the non-assigning party.

C) Headings: Headings used in this MOU are for reference purposes only and shall not be used to modify the meaning of the terms and conditions of this MOU.

D) Entire Agreement: This MOU represents the entire understanding and MOU between the parties with respect to the subject matter hereof, and supersedes all prior and contemporaneous communications, representations or agreements, oral or written, regarding the subject matter hereof.

E) Counterparts: This MOU may be executed in two or more counterparts, each of which shall be deemed an original but all of which shall constitute the same MOU. This MOU and any document or schedule required hereby may be executed by facsimile signature that shall be considered legally binding for all purposes.

F) Confidentiality: In recognition of the confidential nature of this MOU and information developed or received hereunder Receiving Party shall not disclose or convey without the prior written consent of Disclosing Party any such technical information received from Disclosing Party or developed under this Agreement to any other party for the duration of the project and for a minimum period of ten (10) years from the date of project completion, termination or short closure. Receiving Party shall establish adequate procedures to prevent such transmittal of such technical information by its current employees.

The undertakings in Articles F shall not apply to the following:

- i. Information which is necessarily disclosed to third parties to enable the performance of work to be carried out in connection with this MOU, provided that the third party receiving the information enters into an agreement to keep the information confidential in accordance with this Article F;
- ii. Information which is ordered to be disclosed by a court of competent jurisdiction;
- iii. Information which is already in the public domain (except because of any breach of this undertaking);
- iv. Information which the party receiving the information can demonstrate from written records was already known to it at the time of receipt of such information from the party disclosing the information.

AGREED AND ACCEPTED:

Centurion University of Technology & Management, Balangir

Energy Efficiency Services Limited

Name:

Designation:

Address:

Name:

Designation:

Address:

5th & 6th Floor, Core-3

SCOPE Complex, 7-Lodhi Road

New Delhi-110003

WITNESS

12.0 ENERGY MANAGEMENT POLICY

Energy management policy provides the foundation for setting performance goals and integrating energy management into an organization's culture. It is a well-known fact that a formal written energy policy acts both as: A public expression of an organization's commitment to energy management and working document to guide energy management practices and provides continuity.

It is the organization's best interest that support for energy management is expressed in a formal written declaration of commitment accompanied by a set of stated objectives, an action plan for achieving them and clear specifications of responsibilities.

The format of energy policy statement is various, but it usually includes the goal or objective of the organization and the more concrete targets in the field of Energy Management (or Energy Conservation). It often shows the major measures and time tables. The statement shall match the organization's mission statement or overall management strategy plan.

The guiding principle of the proposed energy conservation policy should include

- To endeavor for reduction in Specific Consumption of Energy in all forms and in all areas of operations.
- To ensure availability of information and necessary resources for achieving objectives and targets.



- To comply with all applicable legal, regulatory and other requirements related to energy use, consumption and efficiency.
- To espouse Energy Efficient Technology encompassing procurement of Energy Efficient Products and services and design for Energy Performance Improvement.
- To carry out Energy Audits and Energy Reviews at planned intervals to improve Energy performance.

Actual drafting / reviewing of energy policy will depend upon an organizations corporate culture and management style. We feel that the policy will get wider acceptance if all the concerned parties have been given the opportunity to contribute to the proposed amendment. All departmental representatives should be invited to make submission when the policy is reviewed. After the policy is reviewed, it should be approved by the Board and it should be formally adopted. Further it is recommended to form a energy conservation cell in CUTM in which faculty members from electrical department, utility managers, finance manager and senior management representative to be there. They should organize regular monthly meeting and awareness program in the campus. They should also explore possibilities for implementation of energy efficiency and renewable energy project.



Annexure:

1. Format of Energy Bill:

SUMMARY OF ENERGY BILL OF ----- FOR FINANCIAL YEAR -----																			
Month	Energy Consumed in kWh	Av. Load Factor	Av. Power Factor	MD in kW	MD in kVA	Energy Charge in Rs.	Demand Charge in Rs.	PF Penalty (+ve) / PF Incentive (-ve)	Rebate	CSC	TOD Incentive	Overdraw Penalty	Delay Payment Surcharge	Interest on Security	Meter Rent in Rs.	Electricity Duty	Current Monthly Bill in Rs.	Energy Charge in Rs./kWh	Unit cost in Rs. per kWh
Apr																			
May																			
Jun																			
Jul																			
Aug																			
Sep																			
Oct																			
Nov																			
Dec																			
Jan																			
Feb																			
Mar																			
Total / Av.																			
Monthly Average																			
Daily Average																			

2. **Technical Specification of DG Set & Energy Data Sheet of DG:**

Energy Data Sheet of -----kVA DG Set for FY -----			
Month	Diesel Consumption in kL	Total Energy Generated in DG Set in kWh	SEC in Liter/kWh
Apr			
May			
Jun			
Jul			
Aug			
Sep			
Oct			
Nov			
Dec			
Jan			
Feb			
Mar			
Total			

3. **Technical data sheet of ----- Transformers & Transformer Performance Assessment:**

Technical data sheet of ----- Transformers	
Particulars	TRF no.-----
Make	
Transformer rated in kVA	
Rated voltage ratio in kV	
Rated current ratio in Amp	
No. of phase	
Vector diagram	
Type of cooling	
Measured voltage at LT side in kV	
Measured current LT Side in Amp	
Measured Power Factor	

Transformer Performance Assessment	
Details	TRF no.-----
Transformer Rating in KVA	
Measured voltage at LT side in kV	
Measured current in LT Side Amp	
No Load Loss (kW)	
Full Load Loss of Transformer (kW)	
Measured load (kVA)	
% Loading on the Transformer (Measured kVA/ Rated kVA)	
Actual Losses of Transformer (kW)	
Operating Power Factor	
Total Actual Power Delivered by Transformer in kW	
Transformer Efficiency, %	
Transformer performance	

4. LUX Measurement

LUX Measurement		
Area	Measured LUX	Recommended LUX

5. Energy Management Training Program Log Sheet

Energy Management Training Program of CUTM, Paralakhemundi															
Sl. No.	Energy Committee Members	Designation	Ph. No.	April	May	June	July	August	September	October	November	December	January	February	March



13.0 Vender Details of Projects

Vender details for CUTM						
Sl. No	Vendor Name	Service	Address	Phone Number	Email	Website
1	Star Enterprises	Solar Water Heater	205A, Snehalata Apartment, Vivekananda Marg, Bhubaneswar-751002	9040310328/7008527362	starenterprisesbbsr@gmail.com	
2	Lavancha Renewable Energy Pvt.	Solar Water Heater	Ltd. Regus CBD, Level 9, East Wing, Raheja Towers, MG Road, Bengaluru – 560001	99006 66885 / 7348907677	niranjan.patil@lavancha.in / info@lavancha.in	https://www.lavancha.in/
3	Sky shade Daylights Pvt Ltd	Light Pipe system	#401, Jyothi Flora, Plot no. 240, B-Block, Kavuri hills, Madhapur, Hyderabad-500081	91-40 4020 4022/33	marketing@skyshade.in	www.skyshade.in



4	Tanstate Global	Light Pipe system	Regulus, S No 1/10/2, B 801, Balewadi Near PMC School Pune 411045	7219700559	tanstateglobal@gmail.com / tsg@tanstateglobal.com	http://www.tanstateglobal.com
5	KRISHNA ENGINEERS & CONSULTANTS	Biogas Plant	Plot No: 4723, Laxmi Vihar, Lane-3, Sainik School, Bhubaneswar, Odisha, India- 751005	09114160231, 09437256123	krishnaenergy@gmail.com / krishnaenergy2@gmail.com	www.krishnaenergy.com
6	Energy Efficiency Services Limited	AC Replacement	Ground Floor, House No. 409/B, Sahid Nagar, Bhubaneswar, Dist. Khordha Odisha – 751007.	9861486746	info@power-tech.group	
7	Energy Efficiency Services Limited	28W Super Energy Efficient Ceiling Fan	Ground Floor, House No. 409/B, Sahid Nagar,	9861486746	info@power-tech.group	



			Bhubaneswar, Dist. Khordha Odisha - 751007.			
8	Solar Sack (A unit of Nemhans Solution Pvt. Ltd)	Solar Rooftop Project	N4/234,IRC Village, Nayapalli, Bhubaneswar	9238412384	quotation@solarsack.in	
9	UNIFY SOLAR	Solar Rooftop Project	DELHI	9212560106, 9667966755	unifysolar@gmail.com	http://www.unifysolar.in